

UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4082301

Days Creek School	Project: Drinking Water	Date Reported: 08/29/24
P O Box 10	Project #: Lead/Copper 2024	Date Received: 08/23/24 08:55
Days Creek, OR 97429	Client Contact: Eli Jenks	Sampled By: Eli Jenks
	PWSID#: 4192101	

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4082301-01	Sample Location: Kitchen Sink									
	Lead (‡)	1030	0.002	mg/L	0.001	0.015	08/23/24 06:10	08/27/24	DST	
	Copper (‡)		0.039	mg/L	0.010	1.3	08/23/24 06:10	08/27/24	DST	
4082301-02	Sample Location: Room 208									
	Lead (‡)	1030	0.028	mg/L	0.001	0.015	08/23/24 06:14	08/27/24	DST	CON-1
	Copper (‡)		0.022	mg/L	0.010	1.3	08/23/24 06:14	08/27/24	DST	
4082301-03	Sample Location: HS Hall DF									
	Lead (‡)	1030	ND	mg/L	0.001	0.015	08/23/24 06:17	08/27/24	DST	
	Copper (‡)		0.012	mg/L	0.010	1.3	08/23/24 06:17	08/27/24	DST	
4082301-04	Sample Location: Breakroom									
	Lead (‡)	1030	0.008	mg/L	0.001	0.015	08/23/24 06:20	08/27/24	DST	
	Copper (‡)		0.023	mg/L	0.010	1.3	08/23/24 06:20	08/27/24	DST	
4082301-05	Sample Location: Concession Stand									
	Lead (‡)	1030	ND	mg/L	0.001	0.015	08/23/24 06:27	08/27/24	DST	
	Copper (‡)		0.086	mg/L	0.010	1.3	08/23/24 06:27	08/27/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4082301

Qualifiers and Definitions


CON-1	Results confirmed by duplicate analysis.
DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Dan Phillips, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
 Myrtle Creek, Oregon 97457
 (541) 863-5201 Fax: (541) 863-6199
 E-mail: Lab@URCmail.net
 Internet: http://ChemLab.cc
 ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4082303

Days Creek School	Project: Drinking Water	Date Reported: 09/05/24
P O Box 10	Project #: Lead Sampling	Date Received: 08/23/24 08:55
Days Creek, OR 97429	Client Contact: Eli Jenks	Sampled By: Eli Jenks
	PWSID#: 4192101	

Method: USEPA 200.8

Matrix: Drinking Water


	Sample Location	Code	Result	Units	MRL	MCL	Sampled	Analyzed	Analyst	Qualifier
4082303-01	Sample Location: Room 201									
	Lead (±)	1030	9.1	ppb	1.0	15	08/23/24 06:00	08/26/24	DST	
4082303-02	Sample Location: Room 202									
	Lead (±)	1030	10.0	ppb	1.0	15	08/23/24 06:01	08/26/24	DST	
4082303-03	Sample Location: Room 203									
	Lead (±)	1030	12.6	ppb	1.0	15	08/23/24 06:02	08/26/24	DST	
4082303-04	Sample Location: Room 204									
	Lead (±)	1030	ND	ppb	1.0	15	08/23/24 06:04	08/26/24	DST	
4082303-05	Sample Location: Room 205									
	Lead (±)	1030	13.7	ppb	1.0	15	08/23/24 06:05	08/26/24	DST	
4082303-06	Sample Location: Elementary DF									
	Lead (±)	1030	ND	ppb	1.0	15	08/23/24 06:06	08/26/24	DST	
4082303-07	Sample Location: Room 207									
	Lead (±)	1030	2.6	ppb	1.0	15	08/23/24 06:12	08/26/24	DST	
4082303-08	Sample Location: AG DF									
	Lead (±)	1030	ND	ppb	1.0	15	08/23/24 06:25	08/26/24	DST	
4082303-09	Sample Location: Gym DF									
	Lead (±)	1030	1.1	ppb	1.0	15	08/23/24 06:27	08/26/24	DST	
4082303-10	Sample Location: Gym Lobby DF									
	Lead (±)	1030	ND	ppb	1.0	15	08/23/24 06:34	08/26/24	DST	
4082303-11	Sample Location: Gym Lobby Girls RS									
	Lead (±)	1030	1.7	ppb	1.0	15	08/23/24 06:37	08/26/24	DST	
4082303-12	Sample Location: Gym Lobby Boys RS									
	Lead (±)	1030	ND	ppb	1.0	15	08/23/24 06:38	08/26/24	DST	

UMPQUA Research Company/MC

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.

Dan Phillips, Laboratory Manager



UMPQUA Research Company

626 NE Division St. - P.O. Box 609
Myrtle Creek, Oregon 97457
(541) 863-5201 Fax: (541) 863-6199
E-mail: Lab@URCmail.net
Internet: <http://ChemLab.cc>
ORELAP ID# OR100031

ANALYSIS REPORT

URC # 4082303

Qualifiers and Definitions

DET	Analyte DETECTED
ND	Analyte NOT DETECTED at or above the MRL (minimum reporting limit)
NA	Not Applicable
NR	Not Reported
dry	Sample results reported on a dry weight basis
RPD	Relative Percent Difference
MRL	Minimum Reporting Limit
MDL	Minimum Detection Limit
MCL	Maximum Contamination Level
(‡)	ORELAP Accredited Analyte
(~)	Due to rounding of individual analytes, the "total" may vary slightly from the sum of the individual analyte values.

UMPQUA Research Company/MC

Dan Phillips, Laboratory Manager

The results in this report apply to the samples analyzed in accordance with the chain of custody document.

This analytical report must be reproduced in its entirety.